Pre-permit swimming pool checklist

This checklist is designed to guide the pool operator in assessing the permit status of each pool prior to pre-opening inspections. Please review each item listed as it appears on our inspection report. Place a check next to each item when you are sure that it meets the requirements of the corresponding rule. Please note the any (6) point item that does not meet requirements will result in permit suspension requiring a follow-up inspection and a reinspection charge, 6 point items are: *1, *2, *3, *4, *6, *15 and *22

Place an (X) next to each item only if 100% in compliance. Thank You

| | | 1 | | |
|-----------------|---|--------|---|--|
| | ATER QUALITY: (.2535) | • | | |
| *I. | Vater clear enough to clearly see hottom of pool and pool drain | | *(1) violation of rule 18A.2535(2) water clarity | |
| *2. | Disinfectant residual provided by: | | *(2) violation of rule 18A.2531(a)(11)2531(b)(3) | |
| | free chlorine = (at least 1.0 ppm or 2.0 ppm where required); | | .2535(3)(4)(5)(7)(8)(9) | |
| | bromine = (at least 2.0 ppm); or | | .2543(d)(7) or (c)(2) | |
| | biguanide =(30 to 50 ppm) | 6 | (4)(4) 44 (4)(4) | |
| *3. | Pool water pH =(7.2 to 7.8) | 6 | (3) violation of rule .2535(1) water ph. | |
| * 4. | Water temperature of heated pool F; does not exceed 90 F | | (4) violation of rule .2531(12) water temperature | |
| *5. | (swimming pool) or 140 F (spa) | 6 | , | |
| | | 4 | | |
| PO | OL MAINTENANCE: | | 3 | |
| *6. | Main drain covers secured and in good repair, no suction hazard. Single | | | |
| 7 | drains protected by April 1, 2006 (.2537, .2539) | 6 | (6) violation of rules .2518(k), 2537(b)(7) or (16), or (.2537) | |
| 7. 8. | Pool walls and floor kept clean, free of debris and in good repair (.2537) Surface skimmers (with weirs, baskets and covers) or gutters clean, in good | 4 | | |
| ٠. | repair, and functioning properly, no floating debris (.2518, .2537) | 4 | Notes All audious-last and the state of the | |
| 9. | Depth markings and no diving markers or signs visible and properly located | 4 | Note: All swimming pools or spas with single line drains | |
| ••• | (.2523, .2537) | 4 | must be equipped with a safety vacuum release system. | |
| 10. | Safety ropes with floats and contrasting color bands provided at shallow area | ** | | |
| | breakpoints (2515, .2523) | 2 | | |
| 11. | Diving equipment, ladders, steps and handrails properly placed in equit repair | | | |
| 12. | (.2517, .2521) Inlets and other fittings in place and in good repair (.2537) | 2 4 | | |
| 13. | Contrasting band on steps and benches (.2521, .2516, .2532) | 4 | | |
| 14. | Spa timer working properly (.2537) | 4 | | |
| PRI | EMISES: | | | |
| *15. | Body hook and ring buoy with throw rope or lifeguard with rescue tube | | (15) violation of rules .2530 (a) or (b), or .2537 (b)(1) | |
| | provided and properly located (.2530, .2537) | 6 | lifesaving equip. | |
| 16. | Fence or barrier with self-closing, self-latching gates properly constructed and | | | |
| 17 | maintained (.2528, .2537) | 4 | | |
| 18 | Decks unobstructed, properly drained, free of trip hazards (2522, 2537) Lifeguards present or warning signs posted (.2530) | 4 | | |
| 19. | Signs prohibit glass containers or pets in pool area (.2530) | 4 | | |
| 20, | Caution signs posted at hot water spas (2532) | 4 | | |
| 21. | Pool and deck lighting provided at pools that operate at night (.2524, .2537) | 4 | | |
| *22. | Emergency telephone provided (.2530) | 6 | (22) violation of rule .2530 (1) emergency telephone | |
| FOI | UIPMENT ROOM: | | | |
| | Chlorine or bromine automatic feeders that meet NSF Standard 50 (.2535) | | | |
| 24. | Approved pump, filter, and flow meter operating properly (.2518, .2519) | 4 | | |
| 25. | Equipment and chemicals kept in a dry, well-ventilated enclosure (.2533, .2534. | 4 | | |
| | .2537) | 2 | | |
| 26. | Valves and pipes identified by color codes or labels (2518) | 2 | | |
| 21, | Filer backwash discharged through an air gap (.2513) | 2 | | |
| DRI | ESSING AND SANITARY FACILITIES: | | | |
| 28. | Bathhouse or rest rooms accessible; shower sign posted (.2526) | 2 | | |
| 29. | Required lixtures provided, clean, and in good renair (2526) | 2 | | |
| 31. | Approved water source, no cross connections (.2512) Sewage disposed of in a properly operating sewage system (.2513) | 2 | | |
| 32, | Floors smooth, slip-resistant, kept clean (.2526) | 2 | | |
| 33. | Hose bibbs and floor drains provided (.2526) | 2 | | |
| | | | | |

The following is a list of items that must be in compliance before an operation permit can be issued:

- 1. All public swimming pools including those constructed prior to May 1, 1991 shall be maintained and operated in accordance with Rule .2537 (b) (1-16). (Note: A copy of Rule .2537 has been enclosed.)
- 2. Water quality in all public swimming pools shall be maintained in accordance with Rule .2535 (1-12). Please note that Rule .2535 (11) requires that the pool operator shall inspect the pool at least <u>daily</u> and also requires the daily recording of the disinfectant residual, pH, water temperature in heated pools and activities pertaining to pool water maintenance including chemical additions and filter backwash cycles. Weekly recording of total alkalinity and cyanuric acid levels is also required. (Note: A Monthly Pool Record chart is available for you to copy and use.)
- 3. All safety provisions of Rule .2530 shall be met including the placement of proper signage, safety equipment and telephone. The emergency telephone capable of dialing 911 shall be provided and accessible to all pool users. (Note: Effective April 1, 2005 the telephone shall be permanently affixed to a location inside the pool enclosure or outside the enclosure within 75 feet of a bather entrance. The telephone shall be visible from within the pool enclosure or a sign shall be posted indicating the location of the emergency telephone. A sign with legible letters shall be posted at the telephone providing dialing instructions, address of the pool location and the telephone number.)
- 4. Depth and safety markings shall be provided as required in Rule .2523. (Note: A list of Safety and Depth Marking Requirements is enclosed.)
- 5. The owner of a public swimming pool shall provide for the operation of the pool by a person or persons who shall be responsible to the owner for operation, maintenance, pool safety and record keeping. The pool owner shall maintain documentation that the person responsible for operating the pool has been trained on pool equipment operation, disease and injury prevention, pool water chemistry and regulatory requirements for public swimming pools. A pool and spa operator certificate issued by the National Swimming Pool Foundation or other organization which provides training on those subjects shall be accepted as meeting this requirement. Rule .2537 (c)
- 6. Automatic chlorine and bromine feeder pumps shall be automatically prevented from operating when the circulation pump is not in operation. Automatic feeder pumps can be either connected to the same electrical circuit as the pool circulation pump or connected to a pressure or flow sensing switch which will turn the automatic feeder pumps off if the circulation pump is not pumping water through the circulation system. Rule .2535 (6)

| N.C. Department of Health and Human Services Division of Public Health Environmental Health Section Inspection of Swimming Pool | Demerit Score: Date of Insp/Chg _ Status Code: | | Current Facility ID | | | | |
|--|--|--------------------------------|-------------------------------------|------------------------|--|--|--|
| Water Supply: Community Transient Non-Community | Non-Transient Non-Cor Non-Public Water Supp | | ater sample taken today? Inspection | Name Change | | | |
| Wastewater System: Community On-Si | te Systems | | | | | | |
| Name of Establishment: | | _Pool Operator: | | | | | |
| Location Address:Mailing Addr.: | | | | | | | |
| City:State: No | | _City: | | State:Zip: | | | |
| WATER QUALITY: (.2535) | | Points Deducted (Circle) | * Indicates critical item | (6-point demerit) | | | |
| *1. Water clear enough to clearly see bottom of pool as *2. Disinfectant residual provided by: free chlorine =(at least 1.0 ppm or 2.0 pp bromine =(at least 2.0 ppm); or | | 6 | | | | | |
| biguanide = (30 to 50 ppm | ***************************** | 6 | | | | | |
| *3. Pool water pH = (7.2 to 7.8) *4. Water temperature of heated pool °F; d | loes not exceed 90°F | 6 | | | | | |
| (swimming pool) or 104°F (spa) | | 6 | | | | | |
| 5. Daily written records of water quality and test kit kep | t on site | 4 | | | | | |
| POOL MAINTENANCE: *6. Submerged suction outlets meet ANSI/APSP/ICC-1 | 16 2017 Single | | | | | | |
| drains protected. (.2537, .2539) GPM=Field veri | ification complete= | 6 | | | | | |
| Pool walls and floor kept clean, free of debris and in g Surface skimmers (with weirs, baskets and covers) or | | 4 — | | | | | |
| repair, and functioning properly, no floating debris (.2) | 518, .2537) | 4 | | | | | |
| Depth markings and no diving markers or signs visible (2523, 2537) | | 4 —— | | | | | |
| 10. Safety ropes with floats and contrasting color bands pro | | 4 | | | | | |
| breakpoints (.2515, .2523) | | 2 | | | | | |
| (.2517, .2521) | ****************************** | 2 - | | | | | |
| 12. Inlets and other fittings in place and in good repair (.25.13. Contrasting band on steps and benches (.2521, .2516, | | 4 | | | | | |
| 14. Spa timer working properly (.2537) | | 4 | | | | | |
| PREMISES: | | | | | | | |
| *15. Body hook and ring buoy with throw rope or lifegua | | | | | | | |
| provided and properly located (.2530, .2537) | | 6 | | | | | |
| maintained (2528, .2537) | | 4 | | | | | |
| Decks unobstructed, properly drained, free of trip hazard Lifeguards present or warning signs posted (.2530) | | 4 | | | | | |
| 19. Signs prohibit glass containers or pets in pool area(.253 | 0) | 4 | | | | | |
| 20. Caution signs posted at hot water spas (.2532)21. Pool and deck lighting provided at pools that operate at | night (.2524, .2537) | 4 | | | | | |
| *22. Emergency telephone provided (.2530) | | 6 | | | | | |
| EQUIPMENT ROOM: | | | | | | | |
| Chlorine or bromine automatic feeders that meet NSF S Approved pump, filter, and flow meter operating proper | | 4 — | | | | | |
| 25. Equipment and chemicals kept in a dry, well-ventilated | | 7 | | | | | |
| .2537) | | 2 | | | | | |
| 27. Filter backwash discharged through an air gap (.2513). | | 2 | | | | | |
| DRESSING AND SANITARY FACILITIES: | | | | | | | |
| 28. Bathhouse or rest rooms accessible; shower sign posted | | 2 | | | | | |
| Required fixtures provided, clean, and in good repair (.2 Approved water source, no cross connections (.2512) | | 22 | | | | | |
| 31. Sewage disposed of in a properly operating sewage syst | iem (.2513) | 2 | | | | | |
| 32. Floors smooth, slip-resistant, kept clean(.2526) | | 2 | <u></u> | | | | |
| Inspection Conducted by: | | | I.D.# | Comment Sheet Attached | | | |
| Report received by: | ·· | Епъ | 1. <i>U.</i> # | Yes No | | | |

Purpose: General Statute 130A-282 requires the Commission for Public Health to adopt rules governing Public Swimming Pools. 15A NCAC 18A .2511 specifies the contents of an inspection form to record the results of inspections. This form is developed to be used in making inspections of public swimming pools, spas, wading pools and water recreation attractions. Preparation: Local environmental health specialists shall complete the form every time they conduct an inspection. Prepare an original and two copies for: 1. Original to be left with the responsible person. 2. Copy for the local health department. 3. Copy for the Environmental Health Section. Disposition: This form may be destroyed in accordance with Standard-8.B.6.. Inspection Records Disposition Schedule published by the NC Division of Archives and History. Additional forms may be ordered from: Environmental Health Section, 1632 Mail Service Center, Raleigh, NC 27699-1632.

ERS 3960 (Revised 11/23)